CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7271-0047:111 Page 1 of 1

CATEGORY: System Smoke Detectors/Ionization

LISTEE: Rixson-Firemark, 1902 Airport Rd., Monroe, NC 28110
Contact: *Jeff Trull (704) 283-2101 Fax (704) 226-6198

DESIGN: Model *SMOK-CHEK VI* detector module. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, and UL label.

APPROVAL: Listed as smoke detector module for use only with Models *SMOK-CHEK VI* 6PUSH/6PULL door closers/holders (CSFM Listing No. 0047:112).

XLF: 7271-0257:107

*Rev. 06-08-2002

Date Issued: **JUNE 13, 2003** *Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, *Senior Deputy*
Program Manager